

Board of Supervisors

Paul V. Milde, III, Chairman
Meg Bohmke, Vice Chairman
Jack R. Cavalier
Wendy Maurer
Laura A. Sellers
Gary F. Snellings
Robert "Bob" Thomas, Jr.

Thomas C. Foley
County Administrator

October 11, 2017

ADDITIONAL INFORMATION

BID #1012172

1. For **design purposes only**, the basis of design for the fire pole is McIntire Brass Works, Inc. Model 20.
2. To maintain the continuity of maintenance and parts with existing fire stations the vehicle exhaust system shall be limited to a single source manufacturer by Plymovent. Provide a complete code compliant vehicle exhaust capture and removal system.

